

GAYA WATER SUPPLY PROJECT-1 NOVEMBER.2023]

SL. NO	DATE	LOCATION	PH	TURBIDITY	TEMPERATURE	TDS	CONDUCTIVITY	ALKALINITY	CHLORIDES	HARDNESS
1	24.11.2023	WARD.23.DMA.17.	8.49	0.95	23	210	321	246	29.7	240
2	24.11.2023	WARD.19.DMA.14.	8.00	1.6	23	210	321	242	118.8	236
3	27.11.2023	WARD.8.DMA.11	8.10	2.00	22	280	410	220	69.3	218
4	27.11.2023	WARD.9.DMA.10	8.30	0.63	22	210	320	368	59.4	358
5	28.11.2023	WARD.50.DMA.4	8.54	1.01	22	160	270	184	37.6	178
6	28.11.2023	WARD.51.DMA.5	8.39	0.78	22	160	270	200	39.6	184
7	28.11.2023	WARD.52.DMA.6	8.50	0.84	22	160	270	186	37.62	182
8	28.11.2023	WARD.53.DMA.7	8.49	1.14	22	160	270	188	37.6	178
9	28.11.2023	SHRAM VIKASH..1	8.10	0.69	22	400	651	342	99.0	336
10	28.11.2023	PUMP.NO.1 SOUTH STORE	7.89	1.18	22	260	431	204	99.0	196
11	29.11.2023	DHOBIGHAT	7.89	1.06	22	350	570	320	59.40	314
12	29.11.2023	COTTON MILL TOP	7.86	0.38	22	850	1371	520	148.2	510
13	29.11.2023	WARD 7 DMA11.CE	8.10	2.10	22	280	410	224	69.3	220
14	29.11.2023	PANCHYATI AKHARA-4	6.99	2.66	22	650	1061	548	118.80	552
15	29.11.2023	PANCHYATI AKHARA-5	7.91	2.50	22	670	1092	558	118.3	548
16	30.11.2023	WARD 20 DMA 14CE	8.31	1.86	22	210	330	204	118.8	236
17	30.11.2023	WARD 21 DMA 14	8.33	1.21	22	180	299	242	118.8	238
18	30.11.2023	KIRLOSKER 3	7.47	0.89	22	230	348	284	59.4	276
19	30.11.2023	GMC 3	7.43	0.25	22	320	570	336	60.4	318
20	30.11.2023	PUMP.NO.62	7.90	0.21	22	180	298	300	99	296
21	30.11.2023	PUMP.NO.1 NORTH STORE	7.89	0.87	22	180	312	350	79.20	324